

Utilization Rate of Extra High Voltage Substation



| Substation | 109 | 110 | 111 | 112 | 113 |
|---------------|-------|-------|-------|-------|-------|
| Xizhi | 71.1% | 71.2% | 72.6% | 65.2% | 69.8% |
| Shenmei | 66.7% | 60.2% | 69.4% | 64.5% | 67.2% |
| Banqiao | 57.3% | 54.7% | 56.9% | 56.2% | 55.1% |
| Dongshan | 52.9% | 46.1% | 54.1% | 44.2% | 59.2% |
| South Longtan | 41.0% | 19.2% | 28.5% | 34.7% | 41.1% |
| North Longtan | 41.0% | 41.4% | 46.1% | 44.2% | 60.3% |
| East Dinghu | 64.5% | 60.8% | 63.8% | 46.6% | 64.6% |
| West Dinghu | 64.5% | 73.6% | 80.0% | 71.1% | 76.4% |
| Xindou | 54.6% | 33.2% | 35.0% | 32.0% | 36.1% |
| Zhugon | 39.2% | 44.5% | 52.5% | 51.9% | 57.4% |
| Zhuyuan | 41.4% | 55.2% | 55.6% | 55.4% | 60.6% |
| Wufeng | 70.5% | 64.5% | 59.5% | 66.5% | 74.1% |
| Zhonggang | 61.1% | 63.3% | 65.8% | 64.3% | 69.9% |
| Emei | 19.0% | 6.6% | 4.6% | 20.5% | 29.0% |
| Zhangbin | 28.8% | 8.4% | 26.4% | 7.9% | 67.1% |
| Houli | 34.2% | 21.1% | 37.7% | 38.0% | 45.1% |
| Zhongke | 58.8% | 60.6% | 65.4% | 43.6% | 62.5% |
| Nantou | 38.9% | 40.9% | 38.3% | 40.3% | 61.4% |
| Zhonglin | 13.6% | 6.4% | 17.7% | 8.6% | 16.1% |
| Quanxing | 25.3% | 17.4% | 29.3% | 8.2% | 45.8% |
| Gaogang | 21.9% | 14.1% | 8.7% | 19.5% | 22.4% |
| East Nanke | 45.9% | 65.7% | 58.4% | 63.3% | 68.7% |
| West Nanke | 45.9% | 68.8% | 62.5% | 72.0% | 74.5% |
| Lubei | 42.5% | 41.9% | 37.1% | 47.6% | 78.1% |
| South Longqi | 61.8% | 41.5% | 30.0% | 25.7% | 27.9% |
| North Longqi | 61.8% | 79.1% | 54.2% | 63.5% | 75.9% |
| South Jiamin | 63.6% | 60.9% | 72.7% | 56.8% | 68.7% |
| North Jiamin | 63.6% | 69.9% | 56.3% | 59.6% | 44.7% |
| Renwu | 47.4% | 46.2% | 51.0% | 46.8% | 84.4% |
| Mili | 24.3% | 16.2% | 15.6% | 17.1% | 48.9% |
| Dapeng | 37.5% | 24.8% | 35.9% | 28.0% | 62.6% |
| Wujia | 25.3% | 20.8% | 16.2% | 18.9% | 27.3% |
| Gaoxiong | 60.8% | 47.4% | 55.3% | 51.7% | 74.9% |
| Fenglin | 36.2% | 22.9% | 31.4% | 49.4% | 44.6% |